



Parks, Recreation & Forestry STAFF REPORT

MEMO DATE: July 13, 2021

MTG. DATE: July 22, 2021

TO: Parks, Recreation & Forestry Committee

CC:

FROM: Sean Brusegar, CPRP - Director of Parks, Recreation & Forestry

RE: Damaged Electrical Line at Fireman's Park

BACKGROUND:

The underground electrical line that provides power to the open-air shelter (Old Timers Tent) is no longer functional. Every year prior to the Fireman's Festival, a temporary line is run overhead to provide power to that area. This has been happening since at least 2014. A bid has been received to replace the damaged line. The work will include the following:

- New 200amp 120/240volt single phase panel.
- New underground line.
- Install new power to existing light above the panel.
- Removal of old panel.
- Patching of blacktop, final grading, and grass seed.
- Cost: \$7,860.00

Parks & Recreation does not program the open-air shelter, nor do we need power to that area. This project has not been budgeted for.