



SHEET NOTES

1. ALL UNDERGROUND CONDUITS SHALL MINIMUM 1" SCHEDULE 40 PVC AND SHALL INCLUDE A GROUND WIRE SIZED FOR THE CIRCUIT, UNLESS OTHERWISE NOTED.
2. ALL POLE LOCATIONS SHALL BE COORDINATED WITH LANDSCAPE ARCHITECT AND CIVIL ENGINEER PRIOR TO BEGINNING WORK.
3. ALL CIRCUITS SHALL BE ROUTED THROUGH LIGHTING RELAY PANELS AND CONTROLLED VIA PHOTOSENSOR AND TIMECLOCK. PROVIDE ROOF MOUNTED PHOTOSENSOR, FACE SENSOR TOWARDS TRUE NORTH. PHOTOSENSOR AND PHOTOSENSOR CONTROL CAB SHALL BE LIGHTING CONTROL & DESIGN MODEL #OR2400-PCC1 24V0-50M4 WITH MOUNTING BOX.
4. ALL CONDUCTORS SHALL BE #10 AWG CU, UNLESS OTHERWISE NOTED.
5. SITE LIGHTING ALTERNATE FIXTURES SHALL BE OF SIMILAR QUALITY TO THAT SPECIFIED. CONTRACTOR SHALL BE RESPONSIBLE FOR MEETING STATED ILLUMINANCE CRITERIA WITH ALTERNATE FIXTURES. PHOTOMETRIC PLANS SHALL BE SUBMITTED WITH ALTERNATE FIXTURES FOR APPROVAL.
6. BUILDING MOUNTED LIGHT FIXTURES ARE MOUNTED AT VARIABLE HEIGHTS ABOVE THE FINISHED GRADE. REFER TO EXISTING LIGHTING FIXTURE SCHEDULE FOR MOUNTING HEIGHTS. REFER TO ARCHITECT'S ELEVATIONS FOR EXACT LOCATIONS.

ARCHITECT:
 Mitchell and Hugelback Architects, Inc.
 232A West Ashland
 12747 Olive Blvd., Suite 150
 St. Louis, MO 63141
 314-676-3600
 www.mha.us.com

A member company of SH Group, Inc.
 1175 Peachtree Street
 Suite 700
 Atlanta, GA 30309
 Tel: 875-401-0200
 www.spska.com

SHEET KEYNOTES

1. PROVIDE SIGNAGE WITH 277V, SINGLE PHASE CONNECTION FOR SITE SIGNAGE VIA WEATHERPROOF JUNCTION BOX. CIRCUIT SHALL BE ROUTED THROUGH SITE LIGHTING CONTACTOR/TIMECLOCK. COORDINATE EXACT LOCATION WITH LANDSCAPE AND CIVIL DRAWINGS PRIOR TO ROUGH-IN AND INSTALLATION.

PROJECT SILVER EAGLE
 INTERSECTION OF HIGHWAY N & HIGHWAY TT
 VILLAGE OF COTTAGE GROVE, WI

2022-01-24 DD SET
 PROGRESS PRINT
 NOT FOR
 CONSTRUCTION

REVISION:

Sheet Issue Date: 01/14/21
 Job Number: 21054.00
 Drawn By:
 Checked By:
 Drawing Title:

LIGHTING SITE PLAN

KEY PLAN

C	D
B	A

E-101L

1 LIGHTING SITE PLAN
 SCALE: 1" = 100'-0"